

ਆਈ ਕੇ ਗੁਜਰਾਲ ਪੰਜਾਬ ਟੈਕਨੀਕਲ ਯੂਨੀਵਰਸਿਟੀ ਕਪੂਰਥਲਾ

I.K GUJRAL PUNJAB TECHNICAL UNIVERSITY JALANDHAR, KAPURTHALA

ਰਜਿਸਟਰਾਰ ਦਫਤਰ

REGISTRAR OFFICE

Ref.No.IKGPTU/REG/ DR/S&P/202

Dated 11/05/2026

To

All the Concerned/Interested Vendors

Subject:-**Regarding invitation of quotation for Air Cooler (IKGPTU)**

The IKGPTU University intends to purchase **Air Cooler (Specification attached at Annexure "A")** (I.K. Gujral Punjab Technical University) by inviting sealed quotations. Therefore, you are requested to send the sealed quotation (registered Post/speed post/courier) of the item by quoting lowest rates (inclusive of GST). The quotations must reach in the office of Registrar I.K. Gujral Punjab Technical University by 20.05.2026 upto 04:00PM. Quotations will be opened next working day in the office of the Deputy Registrar, Store & Purchase IKGPTU, Kapurthala. The officer or their representative may be present at the time of opening of the quotations. The Supply order will be placed to the firm offering lowest rates.

Terms & Conditions:

1. The Items to be delivered at IKGPTU, Store & Purchase withing 05 days of issuance of supply order.
2. No Advance payment will be made.
3. Payment will be processed after Satisfactory report given by the Concerned Department/Branch.
4. University will not be paying anything extra as the rates invited are inclusive of GST.
5. Please subscribe in the envelop "**Quotation for Air Cooler**" for Store Branch (IKGPTU) and to be opened by committee only.
6. Quotation received through registered post/speed post/courier shall be acceptable.
7. The concerned vendor will be responsible for providing the services till guarantee/warranty as per company policy
8. The rate quoted will be F.O.R. destination inclusive of all taxes.


Deputy Registrar
Store & Purchase

Copy to:-

- 1 .Registrar of kind information
2. DR ITS: for uploading on website

I. K. Gujral Punjab Technical University

Jalandhar Kapurthala Highway, Kapurthala – 144603 Ph:01822-662521, 662525

Website: www.ptu.ac.in Email: registrar@ptu.ac.in

| | |
|--|---------------------------------|
| Minimum Air Capacity of Cooler (m3/hr) | 3000 |
| Capacity of Sump Tank (in litres) | 60 |
| Type of Mounting | Floor Mounted |
| Compliance to Eco-Mark | Yes, as per clause 9 of IS 3315 |

Category Specific Documents

Applicable Specification Document

Special Terms & Conditions

Conformity to Standard and Compulsory use of Standard Marks on the Evaporative Air Coolers (Desert Coolers) has to be followed by manufacturers as per Govt. of India Gazette Notification "S.O. 1114(E), dated 05th March 2024". Copy of notification attached for reference.

Standard

| | |
|--|--|
| Description of stores | Evaporative Air Coolers (Desert Coolers) |
| Conformity of the Specification for Evaporative Air Cooler | As per IS 3315 |
| Fan Motor used on the Evaporative Air Cooler | Fan Motor ISI Marked to IS 996 |



Ask GeMmy

Product Comparison

Product History 2

Generic

| | |
|---|---|
| Material of Enclosure | Plastic Enclosure, Fire Retardant (Ref. cl. 5.1 of IS 3315) |
| Minimum Air Capacity of Cooler (m3/hr) | 3000 |
| Capacity of Sump Tank (in litres) | 60 |
| Filter Pad | Wood Wool / Honey Comb |
| Minimum length of ISI marked power cable from the outer body (in meter) (Ref. cl. 7.3 of IS 3315) | 2 |
| Minimum drain hole size provided with each cooler (in mm) | 10 |
| Type of Mounting | Floor Mounted |
| Provision of castor wheels on Desert Cooler | Yes |
| Rating Voltage (Ref. cl. 8.3 of IS 3315) | 230 - 240 volts, 50 Hz |

Features and Eco-Mark Related Requirement

| | |
|--|---|
| Salient Features (Hint: Switches for speed regulator and fan should be separately) | Fan On/Off Switch, Speed Regulator Switch, Vertical Swing, Pump Set On/Off Switch |
| All the performance requirement of air cooler | As per clause 6 of IS 3315 (latest) |
| Compliance to Eco-Mark | Yes, as per clause 9 of IS 3315 |
| Marking on the Evaporative Air Cooler | As per clause 15 of IS 3315 |
| Additional Requirement | NA |

**Ask GeMmy**

Product Compare

Product History 2

Certifications

| | |
|--|-----|
| Warranty (in years) | 1 |
| Availability of test reports from Central Government Lab/ NABL accredited LAB / ILAC accredited LAB to prove conformity of the specification | Yes |
| Agreed to furnish test reports and certificates to buyer on demand | Yes |

WEB INFO

- Terms of Use
- Website Policies
- Document Help
- Sitemap
- Web Information Manager

NEWS & EVENTS

- Newsroom
- Gallery
- Notifications
- CCM Schedule
- Forums

TESTIMONIALS

TRAINING

- LMS



Ask GeMmy

Product Comparison Facilitators

Product History 2

ABOUT GeM

- Introduction to GeM
- Statistics
- Right to Information
- Analytics
- New on GeM

BRAND GeM

RESOURCES

- GeM Handbook
- OM's/Circulars
- Terms and Conditions
- Policies/Manuals
- Miscellaneous

MOU'S

NEED HELP ?

- FAQs
- Feedback
- Raise a Ticket
- Contact Us